

Water Testing Results Summary - Bend Bridge Charter Academy

Action Level is 15 parts per billion (ppb)

Fixture Location/Description	Fixture ID #	Test Date	Test Result
Kitchen Sink A	9052003-01	5/17/2019	ND
Kitchen Sink B	9052003-02	5/17/2019	ND
Drinking Fountain A	9052003-03	5/17/2019	ND
Drinking Fountain B	9052003-04	5/17/2019	ND
Classroom 1	9052003-05	5/17/2019	0.003
Classroom 3	9052003-06	5/17/2019	0.002
Classroom 4	9052003-07	5/17/2019	0.003
*Classroom 5	9052003-08	5/17/2019	0.017
Classroom 6	9052003-09	5/17/2019	0.012
Classroom B	9052003-10	5/17/2019	0.01
Woman's Restroom	9052003-11	5/17/2019	ND
Men's Restroom	9052003-12	5/17/2019	ND

ND = Non Detect - Lead level is below the set detection limits of 1ppb

* Classroom 5 has a sign posted advising against drinking the water.